

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1170525

Product: Surge protective device (SPD) type 1 and type 2

Type: A9L16632; A9L16633; A9L16634

Rating: L-N: $U_c=350$ V AC; $I_{imp}=12.5$ kA; $I_{max}=50$ kA; $I_n=30$ kA
N-PE: $U_c=255$ V AC; $I_{imp}=50$ kA; $I_{max}=50$ kA; $I_n=30$ kA,
IP40/20

Ordering firm: Schneider Electric Industries SAS
Electropole, 31 rue Pierre Mendès France, FR-38050 Grenoble Cedex 09

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark: Schneider Electric

The test results are stated in the test-report No.: 702215-01/01 of: 04.07.2017


A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed.2:13
(EN 61643-11:2012, IEC 61643-11:2011)

Other data:

The validity of the certificate is limited to: 31.07.2020

27.07.2017

Prague


Mgr. Miroslav Sedláček
Head of Certification Body

Stamp



702215-01