

Northbrook, Illinois • (847) 272-8800
Melville, New York • (631) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 131000 E33139C

ISSUE DATE: October 13, 2000

Page 1 of 2

Issued to: Square D Company
1601 Mercer Road
Lexington, KY. 40517 USA

Report Reference: E33139, April 12, 1996


This is to Certify that
representative samples of: Panelboards, type NF.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)
indicated on this Certificate.


Standard(s) for Safety: UL 67, Panelboards

Additional Information: See Addendum

Only those products bearing the UL Listing Mark should be considered as being covered by
UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control
number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate
UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: 
Tom Skibbs
Underwriters Laboratories Inc.

Review Engineer: 
Jake Killinger
Underwriters Laboratories Inc.

A not-for-profit organization
dedicated to public safety and
committed to quality service



CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 131000-E33139C
ISSUE DATE: October 13, 2000

Page 2 of 2

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

RATINGS

Current - 600 A maximum

<u>Voltage System (V ac)</u>	<u>Single Phase NF</u>	<u>Three phase NF</u>
600 Y/347	1ph - 3w	3ph - 4w or 1ph - 3w
480 Y/277	1ph - 3w	3ph - 4w or 1ph - 3w
208 Y/120	1ph - 3w	3ph - 4w or 1ph - 3w
120/240	1ph - 3w	
240	1ph - 2w or 3ph - 3w	3ph - 3w
240/120 delta		3ph - 4w


Short Circuit


Except for when series connected ratings are employed, these panelboards have SCCR's equal to the lowest interrupting rating of any installed circuit breaker, but not greater than:

100,000 rms sym. amperes at 240 V ac
65,000 rms sym. amperes at 480 Y/277 V ac
25,000 rms sym. amperes at 600 Y/347 V ac

Maximum SCCR's when series connected ratings are employed are:

200,000 rms sym. amperes at 240 V ac and 480 Y/277 V ac
100,000 rms sym. amperes at 600 Y/347 V ac

Engineer: 
Tom Skibbs
Underwriters Laboratories Inc.

Review Engineer: 
Jake Killinger
Underwriters Laboratories Inc.