

Certificate



for European Product Safety
Intertek

Reference No. 1512962

Socket-outlet

Type designation	BBV39663
Certificate holder	Schneider Electric Danmark A/S Lautrupvang 1, DK 2750 Ballerup, DENMARK
The product complies with the standard(s)	IEC 60884-1:2002+A1+A2 SS 428 08 34:2013
Date of expiry	23 June 2020

Additional information in Appendix.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
--------------------	--	-------	-------------------

Signed



Paul Klemets

Date 23 June 2015
Page 1 of 2



Intertek
Appendix

Reference No. 1512962

Technical data

Type designation	BBV39663
Rated voltage (V~)	250
Rated current (A)	2,5
IP-Class	20
Standard sheet	XVIa
Brand name:	Schneider Electric
Product information	Two-pole socket-outlet for class II appliances. Socket-outlet for class II plugs. Thermoplastic, flush mounting, 3 gang with shutters and screw terminals.

Manufacturing site(s) Lexel Fabrika, SIA
Krustpils 35a, LV-1073 Riga,
LATVIA

Safety related parts of the user instructions shall be written in a language acceptable to the country where the product is to be used.

The certificate applies for countries that have sanctioned the use of plugs/outlets according to subject standard sheet and component standard.

This certificate is based on a certificate with ref. No. P15219789 dated 13 May 2015, issued by Nemko AS according to the Nordic Certification Service Agreement.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed 
Paul Klemets Date 23 June 2015

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.