

Certificate



Intertek

for European Product Safety

Reference No. 1714818

Socket outlet

Type designation BBV39663

Certificate holder **Schneider Electric Industries SAS**
35 rue Joseph Monier
FR 92500 Rueil-Malmaison
FRANCE

The product complies with the standard(s) IEC 60884-1:2002 + A1 + A2
SS 428 08 34:2013

Date of expiry 25 July 2022

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed



Leif Söderlund

Date 25 July 2017

Page 1 of 2

**Intertek**
Appendix

Reference No. 1714818

Technical data

Type designation

BBV39663

Rated voltage (V)

250VAC

Rated current (A)

2,5A

Brand name:

Schneider Electric

Product information

Two-pole socket-outlet for Class II appliances.

Standard Sheet XVIa from NEK 502.

Thermoplastic, Flush mounting, 3-gang, with shutters and screw terminals, IP20

Manufacturing site(s)

AS M&P Nurst

Ümarmäe 3, Kärkla

EE-92414 HIIUMAA

ESTONIA

This certificate is based on a certificate with ref. No. P17222019 dated 11 May 2017, issued by Nemko according to the Nordic Certification Service Agreement.

Certification Body

Intertek Semko AB, Product Certification

Place

Kista - Stockholm

Signed

Leif Söderlund

Date

25 July 2017

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.