

Certificate



Intertek


for European Product Safety

Reference No. 1811020

Junction box

Type designation	TED-S13 (357332)
Certificate holder	Schneider Electric Industries SAS 35 rue Joseph Monier FR 92500 Rueil-Malmaison FRANCE
The product complies with the standard(s)	EN 60670-1:2005+A1:2013
Date of expiry	30 August 2023
EU Directive information	According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
Signed	 Paul Klemets	Date	30 August 2018 Page 1 of 2


This certificate is issued in accordance with the terms and conditions set out in the Appendix.

AMP

**Intertek**
Appendix

Reference No. 1811020

Technical data

Type designation: TED-S13 (357332)
Standard Sheet: SS 430 06 18
Trade mark: 
Product information: Circular flush connecting box (hollow wall mounting, 13 mm wall plate) for accessory of grey insulated material. With 6 inlets for 16, 20 and 25 mm conduit with locking spring and 2 knock-outs at the bottom for accessories. Temperature range -25/90°C.

Material content of the box:
No halogen according to EN 50267-2-2:1999.

Manufacturing site(s) Elda-Eltra Elektrotechnika S.A.
ul. Bugno 1
PL-78-400 Szczecinek
POLAND

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

This certificate replaces previously issued ref. No. 1223733 dated 17 December 2009 for Schneider Electric Sverige AB.

A new certificate has been issued on account of renewal of certificate and updated standard.

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed

Paul Klemets*Date* 30 August 2018

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.