

Certificate



Intertek


for European Product Safety

Reference No. 1815612

Socket-outlet

Type designation	F0320
Certificate holder	Schneider Electric Industries SAS 35 rue Joseph Monier FR 92500 Rueil-Malmaison FRANCE
The product complies with the standard(s)	IEC 60884-1:2002 + A1 + A2 SS 428 08 34:2013 SFS 5610:2015+A11
Date of expiry	30 November 2023

Additional information in Appendix.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
Signed	 Henrik Wikström	Date	30 November 2018

Page 1 of 2

This certificate is issued in accordance with the terms and conditions set out in the Appendix.

**Intertek
Appendix**


Reference No. 1815612

Technical data

Type designation	F0320
Rated Voltage (V)	250~
Rated Current (A)	16
IP-Class	20
Standard sheet	III
Trade mark	Schneider Electric
Product information:	Flush-type socket-outlet, one-fold, 2P+E, with screwless terminals and with shutters. Can be provided with lid.

Manufacturing site(s) Eida-Eltra Elektrotechnika S.A.
ul. Bugno 1
PL-78-400 Szczecinek
POLAND

This certificate is based on CB with ref. No. ES1957 dated 22 January 2018, issued by AENOR INTERNACIONAL S.A U.

<i>Certification Body</i>	Intertek Semko AB, Product Certification	<i>Place</i>	Kista - Stockholm
<i>Signed</i>	 Henrik Wikström	<i>Date</i>	30 November 2018

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.