



中国国家强制性产品认证证书

证书编号: 2004010303134807

委托人名称、地址

Schneider Electric Korea Ltd.
6rd floor, Cheil Bldg, 94-46, Yeongdeungpo-dong 7(Chil)-ga, Yeongdeungpo-gu, Seoul, Korea

生产者(制造商)名称、地址

Schneider Electric Industries SAS
31 Rue Pierre Mendes France, 38050 Grenoble Cedex 9 France

生产企业名称、地址

Schneider Electric Korea Ltd.
574 Yongjae-Dong, Iksan City, Jun Book, KOREA

产品名称和系列、规格、型号

电子式过载继电器

LR97D; Ith:3A; AC-15:Ue/ Ie :250V/3A; DC-13: Ue/ Ie :30V/1A; 具体型号解释见附件

产品标准和技术要求

GB 14048.5-2008

上述产品符合强制性产品认证实施规则
CNCA-01C-011:2007的要求, 特发此证。

发证日期: 2011年05月13日 有效期至: 2016年05月13日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2004年11月15日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2004010303134807

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Korea Ltd.
6rd floor, Cheil Bldg, 94-46, Yeongdeungpo-dong 7(Chil)-ga, Yeongdeungpo-gu, Seoul, Korea

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS
31 Rue Pierre Mendes France, 38050 Grenoble Cedex 9 - France

NAME AND ADDRESS OF THE FACTORY

Schneider Electric Korea Ltd.
574 Yongjae-Dong, Iksan City, Jun Book, KOREA

NAME, MODEL AND SPECIFICATION

Electronical Overload Relay
LR97D; Ith:3A; AC-15:Ue/ Ie :250V/3A; DC-13: Ue/ Ie :30V/1A;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: May. 13, 2011 Date of expiry: May. 13, 2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Nov. 15, 2004

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 0401997



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2004010303134807

纸号: 401997

型号的解释(Explanation of model/ type):

<u>LR97D</u>	<u>38</u>	<u>M7</u>
1	2	3

1. Series Designation

LR97D: LR97D Series

2. Maximum Current Rating

015: 0.3 - 1.5 A (过电流脱扣特性未经验证)

07: 1.2 - 7 A (过电流脱扣特性未经验证)

25: 5 - 25 A (过电流脱扣特性未经验证)

38: 20 - 38 A (过电流脱扣特性未经验证)

3. Control Voltage

B : 24 VAC/DC, 50/60Hz

E : 48 VAC/DC, 50/60Hz

F7: 100/110VAC, 50/60Hz

M7: 200/220/240VAC, 50/60Hz

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

