

CERTIFICATE OF COMPLIANCE

Certificate Number 20120517 – E84967
Report Reference E84967 – 1992 March 20
Issue Date 2012 May 17
Issued to: SCHNEIDER ELECTRIC USA INC / SQUARE D CO
1010 AIRPARK CENTER DR
NASHVILLE, TN 37217 USA

This is to certify that representative samples of **Circuit Breakers, Molded Case and Circuit-breaker Enclosures**
Branch circuit breakers, Type QOA and QOB 2-pole common trip.
(See following page for additional model information.)

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: **ANSI/UL 489, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures" and CAN/CSA-C22.2 No. 5-02, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures."**

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:

 the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.

William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20120517 – E84967
Report Reference E84967 – 1992 March 20
Issue Date 2012 May 17

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Interrupting and Electrical Ratings:

<u>Breaker Type</u>	<u>Interrupting Rating</u>	<u>Reference Fig.</u>	<u>Breaker A</u>	<u>Rating V</u>	<u>Cat. No.</u>
*QOA, QOB	10 kA	1, 3	70-100 @	120/240	QO270 - QO2100 QOB270 - QOB2100
QOA, QOB	10 kA(+)	1, 3	40-100	240	QO240H - QO2100H QOB240H - QOB2100H
QOA, QOB	5 kA(++)	1, 3	40-100	240 1-3 1PH-3PH	QO240H - QO2100H QOB240H - QOB2100H
QOA, QOB	22 kA	1, 3	40-100	120/240	QO240VH - QO2100VH QOB240VH - QOB2100VH
QOA, QOB	42 kA	1, 3	40-100	120/240	QOH240 - QOH2100 QOHB240 - QOHB2100

(+) - Same construction as 1 phase-3 phase rating.

(++) - This 5,000 A rating is for breakers rated 1 phase-3 phase.

* @ - 70 A rating is available in ring terminal construction only.

William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

