

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130521-E201954  
**Report Reference** E201954-20130517  
**Issue Date** 2013-MAY-21

**Issued to:** SCHNEIDER ELECTRIC USA INC / SQUARE D CO  
1010 AIRPARK CENTER DR  
NASHVILLE TN 37217

**This is to certify that  
representative samples of**

SWITCHGEAR ASSEMBLIES, METAL ENCLOSED, LOW-  
VOLTAGE-POWER CIRCUIT-BREAKER TYPE  
Power Zone 4

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:**

UL-1558, STANDARD FOR METAL-ENCLOSED LOW-  
VOLTAGE POWER CIRCUIT BREAKER SWITCHGEAR  
IEEE C37.20.7, GUIDE FOR TESTING METAL-  
ENCLOSED SWITCHGEAR RATED UP TO 38 KV FOR  
INTERNAL ARCING FAULTS


**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Classification Mark should be considered as being covered by  
UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle: with the word "CLASSIFIED"  (as shown); a control  
number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of  
the product; and the product category name (product identity) as indicated in the appropriate UL  
Directory.

Look for the UL Classification Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

