

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140106-E361185  
**Report Reference** E361185-20140101  
**Issue Date** 2014-JANUARY-06

**Issued to:** MERLIN GERIN, DBA SCHNEIDER ELECTRIC  
INDUSTRIES S A S  
ELECTROPOLE/EYBENS, POWER / LV, 31 RUE PIERRE  
MENDES FRANCE,  
38050 GRENOBLE CEDEX 9 FRANCE

**This is to certify that  
representative samples of**

SWITCHES, MOLDED CASE, FOR USE IN  
PHOTOVOLTAIC SYSTEMS


Molded case switches PowerPact U with suffix UD rated  
250A, 300A, 400A and 500A; 600 Vdc for 3 poles and 1000  
Vdc for 4 poles, with poles wired in series.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** UL 489B - Outline of Investigation for Molded-Case Circuit  
Breakers, Molded-Case Switches, and Circuit-Breaker  
Enclosures for Use with Photovoltaic (PV) Systems

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's  
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the  
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category  
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

