



中国国家强制性产品认证证书

证书编号: 2014010304727657

委托人名称、地址

施耐德电气制造(武汉)有限公司
湖北省武汉市东湖开发区珞瑜路546号科技会展中心二期8楼807室

生产者(制造商)名称、地址

施耐德电气制造(武汉)有限公司
湖北省武汉市东湖开发区珞瑜路546号科技会展中心二期8楼807室

生产企业名称、地址

施耐德电气制造(武汉)有限公司
湖北省武汉市东湖新技术开发区佛祖岭三路一号

产品名称和系列、规格、型号

交流接触器

LC1R25(型号解释详见附件); U_i :690V; I_{th} =32A; U_e/I_e :AC-3:AC220V/230V/25A, 380V/25A, 660V/16.5A; AC-4:AC220V/230V/20.9A, 380V/20.9A, 660V/13.8A; U_s :AC24V/36V/48V/110V/220V/380V 50Hz; 3P; 1P20; 配用的辅助触头(本体):1NC, 1NO; I_{th} =10A; U_e/I_e :AC-15:AC380V/1.3A, 660V/0.75A; DC-13:DC220V/0.3A

产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求,特发此证。

发证日期: 2015年07月24日 有效期至: 2019年11月04日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期: 2014年11月04日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1185670



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010304727657

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
Room 807, 8F, Phase II Wuhan Science & Technology Conference & Exhibition
Center, No.546 Luoyu Road, Donghu Hi-Tech Development Zone, Wuhan, Hubei
Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
Room 807, 8F, Phase II Wuhan Science & Technology Conference & Exhibition
Center, No.546 Luoyu Road, Donghu Hi-Tech Development Zone, Wuhan, Hubei
Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
No.1 3rd Fozuling Road, Donghu New&High Tech Development Zone, Wuhan,
Hubei Province, P.R.China

NAME, MODEL AND SPECIFICATION

AC Contactor

LC1R25;U_i:690V;I_{th}=32A; U_e/I_e:AC-3:AC220V/230V/25A, 380V/25A, 660V/16.5A;
AC-4:AC220V/230V/20.9A, 380V/20.9A, 660V/13.8A;
U_s:AC24V/36V/48V/110V/220V/380V 50Hz;3P;IP20; Auxiliary
Contact:1NC, 1NO;I_{th}=10A; U_e/I_e:AC-15:AC380V/1.3A, 660V/0.75A, DC-
13:DC220V/0.3A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Jul.24,2015 Date of expiry: Nov.04,2019

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Nov.04,2014

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1185670



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2014010304727657

纸号: 1185670

型号的解释:

LC1R	25	10	M	5	N	N
I	II	III	IV	V	VI	VII

I	交流接触器基本型号: LC1R 交流接触器经济型基本型号
II	产品规格 25
III	辅助触头类型 10: 1NO 01: 1NC
IV	线圈电压代码 见表 1
V	线圈频率代码(见表 1) 5: 50Hz
VI	N: 中国制造, 国内销售产品
VII	包装形式 TQ: 简易包装 无: 正常包装

表 1

线圈电压代码	电压 - 频率
B5	24V-AC50Hz
CC5	36V-AC50Hz
E5	48V- AC50Hz
F5	110V- AC50Hz
M5	220V- AC50Hz
Q5	380V- AC50Hz

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2014010304727657

纸号: 1185670

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

