



中国国家强制性产品认证证书

证书编号: 2014010304730521

委托人名称、地址

施耐德电气制造(武汉)有限公司
湖北省武汉市东湖开发区珞瑜路546号科技会展中心二期8楼807室

生产者(制造商)名称、地址

施耐德电气制造(武汉)有限公司
湖北省武汉市东湖开发区珞瑜路546号科技会展中心二期8楼807室

生产企业名称、地址

施耐德电气制造(武汉)有限公司
湖北省武汉市东湖新技术开发区佛祖岭三路一号

产品名称和系列、规格、型号

交流接触器

LC1R32; 详见参数附件

产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2015年07月24日

有效期至: 2019年11月04日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2014年11月04日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1185672



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010304730521

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
Room 807, 8F, Phase II Wuhan Science & Technology Conference & Exhibition
Center, No.546 Luoyu Road, Donghu Hi-Tech Development Zone, Wuhan, Hubei
Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
Room 807, 8F, Phase II Wuhan Science & Technology Conference & Exhibition
Center, No.546 Luoyu Road, Donghu Hi-Tech Development Zone, Wuhan, Hubei
Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
No.1 3rd Fozuling Road, Donghu New&High Tech Development Zone, Wuhan,
Hubei Province, P.R.China

NAME, MODEL AND SPECIFICATION

AC Contactor

LC1R32;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Jul.24, 2015 Date of expiry: Nov.04, 2019

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Nov.04, 2014

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1185672



中国国家强制性产品认证证书

附录:

第 1 页 共 3 页

证书编号: 2014010304730521

纸号: 1185672

LC1R32

Ui: 690V;

Ith: 40A;

AC-3: Ue/Ie: 220V/230V/32A, 380V/32A, 660V/20.2A;

AC-4: Ue/Ie: 220V/230V/26.7A, 380V/26.7A, 660V/16.9A;

Us: 24V/36V/48V/110V/220V/380V 50Hz;

极数: 3P;

外壳防护等级: IP20;

配用的辅助触头: (本体)

Ith: 10A;

Ue/Ie: AC-15: 380V/1.3A, 660V/0.75A;

DC-13: 220V/0.3A;

1NC, 1NO

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 3 页

证书编号: 2014010304730521

纸号: 1185672

型号的解释:

LC1R	32	10	M	5	N	TQ
I	II	III	IV	V	VI	VII

I	交流接触器基本型号: LC1R 交流接触器经济型基本型号
II	产品规格 32
III	辅助触头类型 10: INO 01: INC
IV	线圈电压代码 见表 1
V	线圈频率代码(见表 1) 5: 50Hz
VI	N: 中国制造, 国内销售产品
VII	包装形式 TQ: 简易包装 无: 正常包装

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 3 页 共 3 页

证书编号: 2014010304730521

纸号: 1185672

型号的解释: (续)

表 1

线圈电压代码	电压 - 频率
B5	24V-AC50Hz
CC5	36V-AC50Hz
E5	48V- AC50Hz
F5	110V- AC50Hz
M5	220V- AC50Hz
Q5	380V- AC50Hz

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

