



中国国家强制性产品认证证书

证书编号: 2014010304730708

委托人名称、地址

施耐德电气制造(武汉)有限公司
湖北省武汉市东湖开发区珞瑜路546号科技会展中心二期8楼807室

生产者(制造商)名称、地址

施耐德电气制造(武汉)有限公司
湖北省武汉市东湖开发区珞瑜路546号科技会展中心二期8楼807室

生产企业名称、地址

施耐德电气制造(武汉)有限公司
湖北省武汉市东湖新技术开发区佛祖岭三路一号

产品名称和系列、规格、型号

交流接触器

LC1R40, LC1R50, LC1R65 详见参数附件

产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求,特发此证。

发证日期: 2015年07月24日

有效期至: 2019年11月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期: 2014年11月14日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1185671



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010304730708

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
Room 807, 8F, Phase II Wuhan Science & Technology Conference & Exhibition
Center, No.546 Luoyu Road, Donghu Hi-Tech Development Zone, Wuhan, Hubei
Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
Room 807, 8F, Phase II Wuhan Science & Technology Conference & Exhibition
Center, No.546 Luoyu Road, Donghu Hi-Tech Development Zone, Wuhan, Hubei
Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
No.1 3rd Fozuling Road, Donghu New&High Tech Development Zone, Wuhan,
Hubei Province, P.R.China

NAME, MODEL AND SPECIFICATION

AC Contactor

LC1R40, LC1R50, LC1R65 See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Jul.24, 2015 Date of expiry: Nov.14, 2019

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Nov.14, 2014

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:


Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nanshuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1185671



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2014010304730708

纸号: 1185671

LC1R40, LC1R50, LC1R65

Ui: 690V;

LC1R40:

Ith: 60A;

AC-3: Ue/Ie: 220V/230V/40A, 380V/40A, 660V/34.6A;

AC-4: Ue/Ie: 220V/230V/33.3A, 380V/33.3A, 660V/28.8A;

LC1R50:

Ith: 80A;

AC-3: Ue/Ie: 220V/230V/50A, 380V/50A, 660V/37.4A;

AC-4: Ue/Ie: 220V/230V/41.7A, 380V/41.7A, 660V/31.2A;

LC1R65:

Ith: 80A;

AC-3: Ue/Ie: 220V/230V/65A, 380V/65A, 660V/42A;

AC-4: Ue/Ie: 220V/230V/54.2A, 380V/54.2A, 660V/35A;

Us: 24V/36V/48V/110V/220V/380V

极数: 3P;

外壳防护等级: IP20;

配用的辅助触头: (本体)

Ith: 10A;

Ue/Ie: AC-15: 380V/1.3A, 660V/0.75A;

DC-13: 220V/0.3A;

1NO1NC

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2014010304730708

纸号: 1185671

型号的解释:

LC1R	50	M	5	N
I	II	III	IV	V

I	交流接触器基本型号 LC1R 交流接触器经济型基本型号
II	产品规格 40,50,65
III	线圈电压代码 见表 2
IV	线圈频率代码(见表 2) 5: 50Hz
V	N: 中国制造, 国内销售产品

表 2

线圈电压代码	电压 - 频率
B5	24V-AC50Hz
CC5	36V-AC50Hz
E5	48V-AC50Hz
F5	110V-AC50Hz
M5	220V-AC50Hz
O5	380V-AC50Hz

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

