

CERTIFICATE OF COMPLIANCE

Certificate Number 20140106-E361185
Report Reference E361185-20131231
Issue Date 2014-JANUARY-06

Issued to: MERLIN GERIN, DBA SCHNEIDER ELECTRIC
INDUSTRIES S A S
ELECTROPOLE/EYBENS, POWER / LV, 31 RUE PIERRE
MENDES FRANCE,
38050 GRENOBLE CEDEX 9 FRANCE

**This is to certify that
representative samples of**

SWITCHES, MOLDED CASE, FOR USE IN
PHOTOVOLTAIC SYSTEMS


Molded case switches PowerPact T with suffix TB rated
100A, 150A and 200A; 600 Vdc for 3 poles and 1000 Vdc
for 4 poles, with poles wired in series

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 489B - Outline of Investigation for Molded-Case Circuit
Breakers, Molded-Case Switches, and Circuit-Breaker
Enclosures for Use with Photovoltaic (PV) Systems

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

