

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140106-E363533  
**Report Reference** E363533-20131208  
**Issue Date** 2014-JANUARY-06

**Issued to:** MERLIN GERIN, DBA SCHNEIDER ELECTRIC  
INDUSTRIES S A S  
ELECTROPOLE/EYBENS, POWER / LV  
31 RUE PIERRE MENDES FRANCE  
38050 GRENOBLE CEDEX 9 FRANCE

**This is to certify that  
representative samples of**

CIRCUIT BREAKERS, MOLDED CASE AND CIRCUIT-  
BREAKER ENCLOSURES FOR USE IN PHOTOVOLTAIC  
SYSTEMS


Molded case circuit breakers PowerPact U with suffix UC  
and UG rated 225A through 500A for circuit breakers; 600  
Vdc for 3 poles and 1000 Vdc for 4 poles, with poles wired  
in series.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** UL 489B - Standard for Molded Case Circuit Breakers,  
Molded Case Switches and Circuit Breaker Enclosure for  
Use With Photovoltaic (PV) Systems

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's  
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the  
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category  
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

