


# Certificate of Compliance

Certificate Number 271005-E10027  
Report Reference E10027, March 31, 2004  
Issue Date 2005 October 27

Page 1 of 1



*Issued to:* **Square D Co.**  
3700 6th St SW  
Cedar Rapids, IA 52404

*This is to certify that  
representative samples of*

Molded-Case Circuit Breakers

POWERPACT M with Suffix G and J rated 800A. POWERPACT M is a 2 and 3 pole molded case circuit breaker with a maximum frame rating of 800A and a voltage rating of 600 Vac.

*Have been investigated by Underwriters Laboratories Inc.® in  
accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:*


UL 489, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit Breaker Enclosures."

*Additional Information:*

Circuit Breaker Type	Short Circuit Current Rating (kA, rms, sym)		
	240V	480V	600V
Type MG	65(+)	35	18
Type MJ	100(+)	65	25

(+) Two pole breakers may also be rated 240V/65kA, 1-3 phase.

**Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.**

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by: *Hilary Frei*  
**Hilary Frei**  
Underwriters Laboratories Inc.

Reviewed by: *Jeffrey Hidaka*  
**Jeffrey Hidaka**  
Underwriters Laboratories Inc.