

Northbrook, Illinois • (847) 272-8800
Melville, New York • (516) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 290800 - E33139

ISSUE DATE: August 29, 2000

Page 1 of 2

Issued to: Square D Company
1601 Mercer Road
Lexington, KY USA

Report Reference: E33139, October 10, 1984


This is to Certify that representative samples of: Type QMB panelboards and enclosed panelboards, suitable for use with type QMB or QMJ switches, QMB circuit breaker adapters, and type QMBS motor controllers.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 67, Panelboards

Additional Information: See addendum

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: 
Michael J. Maher
Underwriters Laboratories Inc.

Review Engineer: 
Jeffrey Hidaka
Underwriters Laboratories Inc.

CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 290800 - E33139

Page 2 of 2


ISSUE DATE: August 29, 2000


This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Maximum Ratings:

Voltage 600Vac, 250Vdc. Continuous current 1200A (aluminum bus), 1600A (copper bus)
Short circuit 200kA.

These panelboards are rated 480Vac maximum, 3 phase, 3 wire, when used in corner grounded delta applications. The construction with a type QMB main switch has a maximum continuous current rating of 800A.

Engineer: 
Michael J. Maher
Underwriters Laboratories Inc.

Review Engineer: 
Jeffrey Hinaka
Underwriters Laboratories Inc.