



**Underwriters Laboratories Inc.®**

Northbrook, Illinois • (708) 272-8800  
Melville, New York • (516) 271-6200  
Santa Clara, California • (408) 985-2400  
Research Triangle Park,  
North Carolina • (919) 549-1400

# **CERTIFICATE OF COMPLIANCE**

**CERTIFICATE NUMBER:** 311095 - E84967A  
**ISSUE DATE:** October 31, 1995

**Issued to:** Square D Company  
3700 6th Street S.W.  
Cedar Rapids, IA 52404, USA

**Report Reference:** E84967 - December 30, 1970

**This is to Certify that representative samples of:** Molded-Case Circuit Breakers, Type QO and QOB with Catalog Number Prefix QO or QOB

**Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.**

**Standard(s) for Safety:** UL 489, Molded-Case Circuit Breakers and Circuit Breaker Enclosures

**Additional Information:**

*These are one, two & three pole HACR Type circuit breakers with the following ratings:*  
- one & two pole rated 10 thru 70 A maximum, single phase, 120/240 V, 60 Hz  
Current Interrupting Rating is 10kA, 120/240 V ac and 5kA, 48 V dc, AIR  
- three pole rated 10 thru 60 A maximum, three phase, 240 V ac, 60 Hz  
Current Interrupting Rating is 10kA, 240 V ac and 5kA, 48 V dc, AIR

**Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.**

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" - ; the word "Listed"; a control number (may be alphanumeric) assigned by UL; and, the product or category name (product identifier) as indicated in the appropriate UL Directory.

**LOOK FOR THE UL LISTING MARK ON THE PRODUCT**

**Engineer:**   
Underwriters Laboratories Inc.  
Mark R. Barron

**Review Engineer:**   
Underwriters Laboratories Inc.  
Jolanta M. Wroblewska