

Declaration of Conformity

Galaxy VM 160-200 kVA

We, Schneider Electric It Denmark Aps, Silcon Allé, DK-6000 Kolding, hereby declare that the product below conforms to the relevant requirements of the appropriate EU directive. This declaration shall cease to be valid if modifications are made to the equipment without our approval.

- Low Voltage Directive 2014/35/EU
- EMC Directive 2014/30/EU

and that standards and/or technical specifications referenced herein have been applied.

1st affixing of CE marking: August 1st, 2014.

Kolding June 23rd, 2015

Name: Michael Pedersen

Michael Pedersen
992.9212C

Function: Galaxy VM Chief Engineer

The signatories act on behalf of the company management with full power of attorney.

Harmonized Standards

References of standards applied for this declaration of conformity, or parts thereof:

- IEC62040-1:2008-06, 1st edition Uninterruptible Power Systems (UPS) - Part 1: General and safety requirements for UPS.
 - EN62040-1:2013-01, 1st edition amendment 1.
- IEC62040-2:2005-10, 2nd edition Uninterruptible Power Systems (UPS) - Part 2: Electromagnetic compatibility (EMC) requirements.
- IEC62040-3:2011-03, 2nd edition Uninterruptible Power Systems (UPS) - Part 3: Method of specifying the performance and test requirements.
- IEC62040-4:2013-04, 1st edition Uninterruptible Power Systems (UPS) - Part 4: Environmental aspects – Requirements and reporting.
- IEC60950-1:2005-12, 2nd edition Information technology equipment - Safety -Part 1: General requirements.
 - IEC60950-1:2009-12, 2nd edition amendment 1.

Product description

- Uninterruptible Power Systems (UPS).

Galaxy VM UPS System				
GVMPB160KHS	GVMPB200KHS	GVMsb160KHS	GVMsb200KHS	

Galaxy VM Modular Battery Cabinet			
GVMMODBCN(S)	GVMMODBCW(S)	GVMMBTU	

Galaxy VM Classic Battery System				
GVMCBC2NEC	GVMCBC2WEC	GVMCBC3WEC	GVMCBCABWEL	
	GVMCBC2WED	GVMCBC3WED	GVMCBCWEA	

Galaxy VM Battery Breaker Box				
GVMBBB630IEC	GVMBBB630EL			

Galaxy VM System Bypass Cabinet				
GVMSBC640KHEL				

These references may be preceded and/or followed by additional alphanumeric characters in other documents.

