



中国国家强制性产品认证证书

证书编号: 2014010305719634

委托人名称、地址

施耐德万高(天津)电气设备有限公司
天津滨海高新技术产业开发区华苑产业区(环外)海泰创新六路11号

生产者(制造商)名称、地址

施耐德万高(天津)电气设备有限公司
天津滨海高新技术产业开发区华苑产业区(环外)海泰创新六路11号

生产企业名称、地址

施耐德万高(天津)电气设备有限公司
天津滨海高新技术产业开发区华苑产业区(环外)海泰创新六路11号

产品名称和系列、规格、型号

自动转换开关电器

ATMT08, ATMT10, ATMT12, ATMT16, ATMT20, ATMT25, ATMT32, ATMT40, ATMTU08,
ATMTU10, ATMTU12, ATMTU16, ATMTU20, ATMTU25, ATMTU32, ATMTU40; U_i : 1000V;
 U_e : AC415V; I_e : 800A, 1000A, 1250A, 1600A, 2000A, 2500A, 3200A, 4000A; I_{cn} :
65kA; I_{cm} : 143kA(峰值); 电器级别: CB级; AC-33iB; 3P, 4P; 具体型号详见附录

产品标准和技术要求

GB/T 14048.11-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2015年04月14日

有效期至: 2019年09月12日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2014年09月12日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1102916



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010305719634

NAME AND ADDRESS OF THE APPLICANT

Schneider Wingoal(Tianjin) Electric Equipment Co.,Ltd.
No.11, Hi-Tech Chuang Xin No.6 Rd, Hua Yuan Industrial Development Area
(Outside Outer Ring), Binhai New Area, Tianjin P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Wingoal(Tianjin) Electric Equipment Co.,Ltd.
No.11, Hi-Tech Chuang Xin No.6 Rd, Hua Yuan Industrial Development Area
(Outside Outer Ring), Binhai New Area, Tianjin P.R.China

NAME AND ADDRESS OF THE FACTORY

Schneider Wingoal(Tianjin) Electric Equipment Co.,Ltd.
No.11, Hi-Tech Chuang Xin No.6 Rd, Hua Yuan Industrial Development Area
(Outside Outer Ring), Binhai New Area, Tianjin P.R.China

NAME, MODEL AND SPECIFICATION

Automatic Transfer Switching Equipment

ATMT08, ATMT10, ATMT12, ATMT16, ATMT20, ATMT25, ATMT32, ATMT40, ATMTU08,
ATMTU10, ATMTU12, ATMTU16, ATMTU20, ATMTU25, ATMTU32, ATMTU40;Ui:1000V;
Ue:AC415V;Ie:800A, 1000A, 1250A, 1600A, 2000A, 2500A, 3200A, 4000A;Icn:
65kA;Icm:143kA(Peak value);ATSE Class:CB;AC-33iB;3P, 4P;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.11-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Apr.14,2015 Date of expiry: Sep.12,2019

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Sep.12,2014

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1102916



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2014010305719634

纸号: 1102916

型号的解释:

ATMT、ATMTU

① ② ③ ④

- ① 施耐德万高（天津）电气设备有限公司自动转换开关电器缩写；
- ② 额定电流：08：800A； 10：1000A； 12：1250A； 16：1600A； 20：2000A；
25：2500A； 32：3200A； 40：4000A
- ③ 极数：3P：三级； 4P：四极
- ④ 控制器类型：2A、2B、3A、3B、2ARC、2BRC、3ARC、3BRC、TA、TB

注：此附录与证书同时使用时有效。



主任：

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2014010305719634

纸号: 1102916

控制器型式:

2A、2ARC 型—适用两电源;具备主、备回路电源失压、断相、欠压、过压检测及自动、延时转换功能;具有发电机启动触点;电气互锁。2ARC 显示为一块液晶,其功能与 2A 完全相同

2B、2BRC 型—适用两电源;具备主、备回路电源失压、断相、欠压、过压检测及自动、延时转换功能;具备频率、相位和电压幅值差检测功能。2BRC 显示为一块液晶,其功能与 2B 完全相同

3A、3ARC 型—适用两电源—母联的情况;具备主、备回路电源失压、断相、欠压、过压检测及自动、延时转换功能;电气互锁。3ARC 显示为一块液晶,其功能与 3A 完全相同

3B、3BRC 型—适用两电源—母联的情况;具备主、备回路电源失压、断相、欠压、过压检测及自动、延时转换功能;具备频率、相位和电压幅值差检测功能。3BRC 显示为一块液晶,其功能与 3B 完全相同

TA、TB 型—适用三电源的情况;具备电源失压、断相、欠压、过压检测及自动、延时转换功能;具备频率、相位和电压幅值差检测功能。TB 当控制器处于手动模式下,控制器具有短时并联功能。

产品除控制器外所有部分均相同。ATMT 与 ATMTU 除开关颜色不同外其它部分均相同。

本附录与证书同时使用有效。

注: 此附录与证书同时使用有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

