



MET Laboratories, Inc. Safety Certification - EMI - Telecom - Environmental Simulation - NEBS
914 WEST PATAPSCO AVENUE • BALTIMORE, MARYLAND 21230-3432 • PHONE (410) 949-1802 • FAX (410) 354-3313

September 28, 2017

Mr. Jason Lai
American Power Conversion Corp
85 Rangeway Rd Bldg 2
North Billerica, MA 01862
USA

Subject: Amendment to Relocatable Power Taps, Models C2, C2C, C3, C3BLK, C5, C5BLK, G5, G5BLK, P8T3, P8U2XXX, P8T3-CN, P8VT3, P11VT3, P11U2XXX, P11VT3-CN, P11VT3MP6, P11VT3MP10-CN, P11VNT3, P11VNT3-CN, P11GTV, P8V, P8VX577, P8VNTG, P8VNTGX578, For amendment details refer to Attachment 1 page.
Listing Number E113924; MET Project Number 94734
Safety Standards: • ANSI/UL Std. No 1363 (3rd Edition) - Relocatable Power Taps
CSA Std. C22.2 No. 21-95 (R2009) - Cord Sets and Power Supply Cords

Dear Mr. Lai:

Congratulations on successfully completing the MET Certification process for the Relocatable Power Taps. American Power Conversion Corp may begin to apply the MET Mark on the previously identified product at this time in accordance with the MET Mark Utilization Agreement or the MET Applicant Contract. The report covering the above stated product is forthcoming.

Thank you for the opportunity to perform this service for American Power Conversion Corp. We look forward to future opportunities with your company.

Sincerely,

MET LABORATORIES, INC.

Rick Cooper
Director,
Safety Business Line



The Nation's First Nationally Recognized Testing Laboratory
MET Laboratories, Inc. is accredited by OSHA and the Standards Council of Canada.

NRTL

Canadian Certification has been granted under a System 3 program as defined in ISO 17067.



MET Laboratories, Inc. *Safety Certification - EMI - Telecom - Environmental Simulation - NEBS*
914 WEST PATAPSCO AVENUE • BALTIMORE, MARYLAND 21230-3432 • PHONE (410) 949-1802 • FAX (410) 354-3313

Attachment 1
Summary of Amendments/Modifications

1. Change the width of PCB layout trace (not fusible trace part) from 60mil to 20mil for the models P8T3, P8T3-CN, P8VT3, P11VT3, P11VT3-CN, P11VT3MP10-CN, P11VT3MP6, P11VNT3, P11VNT3-CN and P11GTV; see Illustration 6 for new PCB layout trace.



The Nation's First Nationally Recognized Testing Laboratory
MET Laboratories, Inc. is accredited by OSHA and the Standards Council of Canada.

NRTL

Canadian Certification has been granted under a System 3 program as defined in ISO 17067.