



**BUREAU
VERITAS**

08/EK1/1/17800647-1001-1-ENG

Mr. Javier Trillo, Inspector of Group Bureau Veritas, Inspection and Testing certifies

CERTIFIES:

That at the request of the representative of the Company. "SCHNEIDER ELECTRIC INDUSTRIES S.A.S" Mr. J.A Baño (Certifications Manager) and Bureau Veritas as third-party certification, carried out the inspection of the tests described below on the model SFN, SFNHD, SFPN empty enclosures.

In accordance with the requirements of the IEC 62208: 2023, the enclosures SFN, SFNHD, SFPN have obtained **SATISFACTORY** results with the documentation submitted to the inspector and Declaration regarding testing of DEKRA.

Standard specifications IEC 62208:2023

Standard section	Test	Result
Clause 9.3	Marking	SATISFACTORY
Clause 9.4	Verification resistance to static charge.	SATISFACTORY
Clause 9.5	Lifting	SATISFACTORY
Clause 9.6	Mechanical operation	SATISFACTORY
Clause 9.8	Degree of protection against external mechanical impacts (IK code)	SATISFACTORY
Clause 9.9	Degree of protection against access to hazardous parts and against ingress of solid objects and/or water (IP code)	SATISFACTORY
Clause 9.10	Strength of materials and parts, Thermal stability, Resistance to heat, Resistance to abnormal heat and fire	SATISFACTORY
Clause 9.12	Continuity of the protective circuit	SATISFACTORY
Clause 9.13	Resistance to UV radiation	SATISFACTORY
Clause 9.14	Resistance to corrosion	SATISFACTORY
Clause 9.15	Thermal power dissipation capability	SATISFACTORY

In: Barcelona
Date: 13.10.2023

Inspector: Javier Trillo