

IEC

IECEE  
CB  
SCHEME

Ref. Certif. No.

CN23970

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

## CB TEST CERTIFICATE

Product  
Produit

Switche-disconnector

Name and address of the applicant  
Nom et adresse du demandeurSchneider Electric Low Voltage (Tianjin) Co.,Ltd.  
TEDA Mu Ning Road 66#, 7th Avenue, Tianjin, P.R.ChinaName and address of the manufacturer  
Nom et adresse du fabricantSchneider Electric Low Voltage (Tianjin) Co.,Ltd.  
TEDA Mu Ning Road 66#, 7th Avenue, Tianjin, P.R.ChinaName and address of the factory  
Nom et adresse de l'usineSchneider Electric Low Voltage (Tianjin) Co.,Ltd.  
TEDA Mu Ning Road 66#, 7th Avenue, Tianjin, P.R.China

Note: When more than one factory, please report on page 2  
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principalesSW60-DC;Ui=DC1000V;lth=50A;Ue=DC1000V;Ie=50A;  
Icw=600A 0,5s;Icm=1kA;DC-21A; Connection  
diagram:See the Appendix  
Schneider ElectricTrademark (if any)  
Marque de fabrique (si elle existe)Model / Type Ref.  
Ref. De type

SW60 - DC

Additional information (if necessary may also be reported  
on page 2)  
Les informations complémentaires (si nécessaire, peuvent être  
indiqués sur la 2<sup>ème</sup> page)

PUBLICATION

EDITION

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 60947-3:2008(3rd Edition)(2008) in conjunction with  
IEC 60947-1:5th Edition(2007)

As shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

C009-CB2012CQC-041047

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: 2012-07-26

Signature:

Wang Kejiao


Issued 2003-05  
China Quality Certification Centre  
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86-10-83886666  
Fax: +86-10-83886282



website  
www.cqc.com.cn

CB 0016911

CN23970



证书



**TEST REPORT**

**IEC 60947-3**

**Low-voltage switchgear and controigear**

**Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units**

Report Reference No. ....: C009-CB2012CQC-041047

Date of issue .....: 2012-06-07

Total number of pages .....: 27

CB Testing Laboratory .....: Shanghai Testing & Inspection Institute for Electrical Equipment (STIEE)

Address .....: 505 Wu Ning Rd, Shanghai 200063, P.R. CHINA

Applicant's name .....: Schneider Electric Low Voltage (Tianjin) Co., Ltd.

Address .....: TEDA Mu Ning Road 66#, 7th Avenue, Tianjin, P.R. China

**Test specification:**

Standard .....: IEC 60947-3: 3<sup>rd</sup> Edition (2008) in conjunction with IEC 60947-1: 5<sup>th</sup> Edition (2007)

Test procedure .....: CB

Non-standard test method .....: N/A

Test Report Form No. ....: IEC60947\_3B

Test Report Form(s) Originator .....: OVE

Master TRF .....: Dated 2009-08

**Copyright © 2009 Worldwide System for Conformity Testing and Certification of Electrical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved.**

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

**This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.**

Test item description .....: Switch-disconnector

Trade Mark .....: Schneider Electric

Manufacturer .....: Schneider Electric Low Voltage (Tianjin) Co., Ltd.

Model/Type reference .....: SW60-DC

Ratings .....: See page 8



**Testing procedure and testing location:**

**CB Testing Laboratory:** Shanghai Testing & Inspection Institute for Electrical Equipment (STIEE)


Testing location/ address ..... 505 Wu Ning Rd. Shanghai 200063, P.R. CHINA

**Associated CB Test Laboratory:**

Testing location/ address .....

Tested by (name + signature)..... WANG LIYING

Approved by (+ signature) ..... ZHU GANG



Testing procedure: TMP

Testing location/ address .....

Tested by (name + signature).....

Approved by (+ signature) .....

Testing procedure: WMT

Testing location/ address .....

Tested by (name + signature).....

Witnessed by (+ signature).....

Approved by (+ signature) .....

Testing procedure: SMT

Testing location/ address .....

Tested by (name + signature).....

Approved by (+ signature) .....

Supervised by (+ signature) .....

Testing procedure: RMT

Testing location/ address .....

Tested by (name + signature).....

Approved by (+ signature) .....

Supervised by (+ signature) .....

**Summary of testing:****Tests performed (name of test and test clause):**

SW60-DC

Test seq. I, II, III

Test Sequence I:

#01:SW60-DC Ue:DC1000V Ie:50A DC-21A

Test Sequence II:

#02: SW60-DC Ue:DC1000V Ie:50A DC-21A

Test Sequence III:

#03: SW60-DC Ue:DC1000V Ie:50A DC-21A

The Switch-disconnector

SW60-DC

Have passed the type test successfully.

**Testing location:**Shanghai Testing & Inspection Institute for  
Electrical Equipment (STIEE)  
505 Wu Ning Rd. Shanghai 200063. P.R. CHINA**Summary of compliance with National Differences:N/A**