


# TEST CERTIFICATE

No. : C17 / 50273

Client	<b>Schneider Electric Ltd</b> Stafford Park 5 Telford TF3 3BL
Client contact	Mr. Alan Penfield
Item(s) tested	<b>1 &amp; 2 Gang Switched Socket-outlets with twin USB outlets</b> <b>Models:</b> 1 Gang:GGBL30102USBA & 2 Gang: GGL30202USBA (see page 2) <b>Rated :</b> 13A, 250V ~ 50/60Hz Max 0.5A Output: 5V $\equiv$ 2.1A
Specification(s) to which above unit(s) have been tested and compliance confirmed	<b>All Relevant Clause</b> of BS 1363-2: 2016 including Annex I <b>and deemed to comply</b>
Date of issue	11 <sup>th</sup> August 2017
Signed	 ..... <i>Giuseppe Capanna</i> ( Certifying Officer )
Relating to Project File(s) held at Nemko Ltd	50273

To be read in conjunction with page 2 attached



Form No: QF102-1  
Issue No: 6  
Issue Date: 08.03.16



<b>Certificate No:</b>	<b>C17 / 50273</b>
<b>Client:</b>	<b>Schneider Electric Ltd</b>

THIS CERTIFICATE APPLIES ONLY TO THE PARTICULAR SAMPLE UNIT(S) TESTED AND TO THE SPECIFIC TESTS CARRIED OUT AS DETAILED IN THE PROJECT FILE HELD AT NEMKO LTD.

THIS TEST CERTIFICATE DOES NOT COVER ELECTROMAGNETIC COMPATIBILITY.

IT SHOULD BE NOTED THAT ONLY A LIMITED NUMBER OF UNITS HAVE BEEN TESTED. IT IS THEREFORE ESSENTIAL FOR THE MANUFACTURER OR SUPPLIER OF THIS PRODUCT TO ENSURE THAT THE QUALITY OF ALL PRODUCTION UNITS IS OF THE SAME STANDARD AS THAT OF THE SAMPLE(S) CHECKED

LIST OF MODELS COVERED BY THIS REPORT:	
1 Gang	GGBL30102USBA***
2 Gang	Gang: GGL30202USBA***
*** To denote Front plate finish and interior colour as follows:	
BSS	Stainless Steel with Black Interior
WSS	Stainless Steel with White Interior
BPC	Polished Chrome with Black Interior
WPC	Polished Chrome with White Interior
BSB	Satin Brass with Black Interior
WSB	Satin Brass with White Interior
BPB	Polished Brass with Black Interior
WPB	Polished Brass with White Interior
BLC	Light Copper with Black Interior
WLC	Light Copper with White Interior
BMB	Mocha Bronze with Black Interior
WPW	Painted White with White Interior



# Nemko Ltd

<b>Certificate No:</b>	<b>C17 / 50273</b>
<b>Client:</b>	<b>Schneider Electric Ltd</b>

**Condition / number of test sample(s) :** Good / 25    **Serial Number(s) :** -

**Notes relating to this Certificate: -**    Socket-outlet is required to be mounted in a BS 4662 flush metal box or alternatively other boxes complying with the fire enclosure requirements of BS EN 60950-1

**Project History: -**

<u>Job Number</u>	<u>Sample received</u>	<u>Job Completion Date</u>	<u>Summary of work carried out</u>
50273	11-May-17	10-August-17	Full testing to BS 1363-2:2016 + Annex I
50277	11-May-17	28-July-17	BS EN 60950-1 testing of USB modules
50279	11-May-17	28-July-17	BS EN 62680-1-1 testing of USB modules

\*\*\*\*\* END OF CERTIFICATE \*\*\*\*\*

