



Ref. Certif. No.

CN24913-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE**Product
Produit

Control relay

Name and address of the applicant
Nom et adresse du demandeurSchneider Electric Manufacturing (Wuhan) Co., Ltd.
Room 807, 8F, Phase II Wuhan Science & Technology Conference
& Exhibition Center, No.546 Luoyu Road, Donghu Hi-Tech
Development Zone, Wuhan, Hubei Province, P.R.China
Schneider Electric Manufacturing (Wuhan) Co., Ltd.Name and address of the manufacturer
Nom et adresse du fabricantRoom 807, 8F, Phase II Wuhan Science & Technology Conference
& Exhibition Center, No.546 Luoyu Road, Donghu Hi-Tech
Development Zone, Wuhan, Hubei Province, P.R.China
Schneider Electric Manufacturing (Wuhan) Co., Ltd.Name and address of the factory
Nom et adresse de l'usineNo 1 3rd Fozuling Road, Donghu New&High Tech Development
Zone, Wuhan, Hubei Province, P.R.ChinaNote: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} pageRatings and principal characteristics
Valeurs nominales et caractéristiques principalesUi:690V;lth:10A;AC-15:Ue/Ie:220V/2.1A,380V/1.3A,
660V/0.75A; DC-13:Ue/Ie:220V/0.3A; IP20;
Us:50Hz:24V/36V/48V/110V/220V/240V/380V/415V/440V;60
24V/110V/220V/380V/440V;50/60Hz:
24V/48V/110V/220V/380V
Schneider ElectricTrademark (if any)
Marque de fabrique (si elle existe)

CAE22...N,CAE31...N,CAE40...N,CAE22...,CAE31...,CAE40...

Model / Type Ref.
Ref. De typeAdditional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)**PUBLICATION****EDITION**A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laIEC 60947-5-1:2003(3rd Edition)+A1:2009, IEC 60947-
1:2007(5th Edition)+A1:2010As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

C009-CB2012CQC-042547-M1

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification**CHINA QUALITY CERTIFICATION CENTRE**

Date: 2014-03-19

Signature:

Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.ChinaTel: +86-10-83886666
Fax: +86-10-83886282website
www.cqc.com.cn**CB 0024917**