



Ref. Certif. No.

HU-002286

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnector

Name and address of the applicant

Schneider Electric Industrie SAS
31 Rue Pierre Mendès France,
38050, Grenoble Cedex 09, France

Name and address of the manufacturer

Schneider Electric Industrie SAS
31 Rue Pierre Mendès France,
38050, Grenoble Cedex 09, France

Name and address of the factory

SCHNEIDER ELECTRIC ESPAÑA, S.A (SEE)
57 Camino Barranquet,
46133 Meliana, Valencia, Spain

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

2P/4P, Ue=240/415V, Ui=500V, Ie=40/63/80/100A, IP20
(see Test Report for further ratings)

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

iSW-NA ... series
(For type variants see General product information
of the Test Report)

Additional information (if necessary may also be reported on page 2)

The product also fulfils the requirements of
EN 60947-3:2009 + A1:2012 + A2:2015 in conjunction
with EN 60947-1:2007 + A1:2011 + A2:2014

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2008 + AMD1:2012 + AMD2:2015
IEC 60947-1:2007 + AMD1:2010 + AMD2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

28237889 002

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu

Date: 2018-08-24

Signature:

