



Ref. Certif. No.

CN30477-M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
Produit

AC contactor

Name and address of the applicant
Nom et adresse du demandeur

Schneider Shanghai Industrial Control Co., Ltd.
No.629 Suide Road, Putuo District, Shanghai, P.R.China

Name and address of the manufacturer
Nom et adresse du fabricant

Schneider Shanghai Industrial Control Co., Ltd.
No.629 Suide Road, Putuo District, Shanghai, P.R.China

Name and address of the factory
Nome et adresse de l'usine

Schneider Shanghai Industrial Control Co., Ltd.
629 Sui De Road, Pu Tuo District, Shanghai, P.R.C

Note: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

See the appendix

Trademark (if any)
Marque de fabrique (si elle existe)

Schneider Electric

Model / Type Ref.
Ref. De type

LC1E80004...N,LC1E95004...N, LC1E80008...N, LC1E95008...N,
LC1N80004...N,
LC1N95004...N,LC1N80008...N,LC1N95008...N,LC1E80004...LC
1E95004...,LC1E80008...,LC1E95008..., LC1E80004...IN,
LC1E80008...IN

Additional information (if necessary may also be reported
on page 2)

The latest CB certificate No. is CN30477-M1, dated 2017-05-16.

Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)

The second modification is to add other models with IN.

A sample of the product was tested and found
to be in conformity with

Un échantillon de ce produit a été essayé et a été
considéré conforme à la

PUBLICATION EDITION

IEC 60947-1:2007 (5th Edition) + AMD1:2010;IEC
60947-4-1:2009(3rd Edition) + AMD 1:2012

As shown in the Test Report Ref. No. which forms part
of this Certificate

Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

00901-CB2014CQC-058115-M2

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: May.30,2018

Signature: Wang Kejiao

LC1E80004...N,LC1E95004...N, LC1E80008...N, LC1E95008...N, LC1N80004...N,
LC1N95004...N,LC1N80008...N,LC1N95008...N,LC1E80004...,LC1E95004...,
LC1E80008...,LC1E95008..., LC1E80004...IN, LC1E80008...IN

Uimp:6kV

Ui:690V;

Ith(LC1E80004...N,LC1N80004...N,LC1E80004...,LC1E80008...N,LC1N80008...N,
LC1E80008...): 100A;

Ith(LC1E80004...IN,LC1E80008...IN): 110A;

Ith(LC1E95004...N,LC1N95004...N,LC1E95004...,LC1E95008...N,LC1N95008...N,
LC1E95008...):125A

AC-1(LC1E80004... , LC1N80004...N, LC1E80004...N):

Ue/Ie: 220V/230V/380V/400V/415V/440V/660V/690V/100A;

AC-1(LC1E80004...IN):

Ue/Ie: 220V/230V/380V/400V/415V/440V/660V/690V/110A;

AC-3: Ue/Ie: 220V/230V/380V/400V/415V/440V/77.1A, 660V/690V/48.5A;

AC-4: Ue/Ie: 220V/230V/380V/400V/415V/440V/64.3A, , 660V/690V/40.5A;

LC1E80008... , LC1N80008...N, LC1E80008...N, LC1E80008...IN :

AC-1(LC1E80008... , LC1N80008...N, LC1E80008...N):

Ue/Ie: 220V/230V/380V/400V/415V/440V/660V/690V/100A;

AC-1(LC1E80008...IN):

Ue/Ie: 220V/230V/380V/400V/415V/440V/660V/690V/110A;

AC-3: Ue/Ie: 220V/230V/380V/400V/415V/440V/77.1A, 660V/690V/48.5A;

LC1E95004... , LC1N95004...N, LC1E95004...N :

AC-1: Ue/Ie: 220V/230V/380V/400V/415V/440V/660V/690V/125A;

AC-3: Ue/Ie: 220V/230V/380V/400V/415V/440V/84.7A, 660V/690V/48.5A;

AC-4: Ue/Ie: 220V/230V/380V/400V/415V/440V/70.6A, 660V/690V/40.5A;

LC1E95008... , LC1N95008...N,LC1E95008...N :

Page 1 of 2

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: May.30,2018

Signature:



Wang Kejiao

AC-1: Ue/Ie: 220V/230V/380V/400V/415V/440V/660V/690V/125A;
AC-3: Ue/Ie: 220V/230V/380V/400V/415V/440V/84.7A, 660V/690V/48.5A;
Us: AC50/60Hz: 24V, 48V, 110V, 220V, 230V, 240V, 380V, 400V, 415V;
AC50Hz(70%~130%Us): 220V, 415V;
4P;
IP20

Page 2 of 2

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: May.30,2018

Signature: _____



Wang Kejiao