

CN49825-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

AC contactor

Schneider Shanghai Industrial Control Co., Ltd. No.629 Suide Road, Putuo District, Shanghai, P.R.China

Schneider Electric Industries SAS 35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Schneider Electric a. s. Cizovska 447 - 39701 Pisek - Czech Republic

See the Appendix

Schneider Electric

LC1F630, LC1F780, LC1F6304, LC1F7804;

IEC 60947-4-1:2018


00901-CB2019CQC-090420-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86-10-83886666 Fax: +86-10-83886282 website: http://www.cqc.com.cn

Aug.09,2021







CN49825-M1

LC1F630, LC1F780, LC1F6304, LC1F7804

Uimp:8kV;

Ui: 1000V;

LC1F630:

Ith:1000A;

AC-3:Ue/ le:AC230V/608.7A,400V/575A,415V/622.2A,440V/630A,

500V/552A,690V/446.7A,1000V/308.2A;

AC-1:Ue/le:AC230V/400V/415V/440V/500V/690V/1000V/1000A;

3P;

LC1F780:

Ith: 1600A;

AC-3:Ue/le:AC230V/664.9A,400V/690A,415V/704A,440V/780A,

500V/616.5A,690V/469.8A,1000V/308.2A;

AC-1: Ue/le: AC230V/400V/415V/440V/500V/690V/1000V/1600A;

3P;

LC1F6304:

Ith: 1000A;

AC-1:Ue/le:AC230V/400V/415V/440V/500V/690V/1000V/1000A;

4P;

LC1F7804:

Ith: 1600A;

AC-1:Ue/le:230V/400V/415V/440V/500V/690V/1000V/1600A;

4P

Us:AC48V, 110V, 115V, 200-208V, 220V, 230V, 240V, 380V, 400V, 415V,

Page 1 of 2

Additional information (if necessary)

Date: Aug.09,2021

Signature: Xie ZhaoXu

Tel: +86-10-83886666

Fax: +86-10-83886282

website



CN49825-M1

440V(AC40...400Hz); DC48V,110V,125V,220V,250V,440V; AC100-250V 50-60Hz /DC100-380V(only for LC1F630,LC1F6304)

Page 2 of 2

Additional information (if necessary)

Date:

Aug.09,2021



Xie ZhaoXu