



# CB TEST CERTIFICATE

Ref. Certificate No.

NL-41413

## IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Surge protective devices		
Applicant:	Schneider Electric Industries SAS	31 rue Pierre Mendes, Eybens 38050 Grenoble Cedex 9	France
Manufacturer:	Phoenix Contact GmbH & Co. KG	Flachsmarktstraße 8 32825 Blomberg	Germany
Factory:	Phoenix Contact GmbH & Co. KG	Flachsmarktstraße 8 32825 Blomberg	Germany
Rating and principal characteristics:	Uc 440 Vac, Up 2,5 kV, Iimp 35 kA		
Trade mark (if any):	Schneider Electric		
Type of Manufacturer's Testing Laboratories used:	CTF Stage 3		
Model/Type reference:	C1 35-440 (16318) PRD1 35r (16649)		
Additional information:			
Sample of product tested to be in conformity with IEC:	Standard(s): 61643-11(ed.1)		
Test Report Ref. No:	2193624.50		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.  
Meander 1051, 6825 MJ  
Arnhem  
The Netherlands

Signed by: H.R.M. Barends

Date of issue: 2016-05-23

