



Ref. Certif. No.

CN29806-M3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
Produit

AC Contactor

Name and address of the applicant
Nom et adresse du demandeur

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
No.1 3rd Fozuling Road, Donghu New&High Tech
Development Zone, Wuhan, Hubei Province, P.R.China

Name and address of the manufacturer
Nom et adresse du fabricant

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
No.1 3rd Fozuling Road, Donghu New&High Tech
Development Zone, Wuhan, Hubei Province, P.R.China

Name and address of the factory
Nome et adresse de l'usine

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
No.1 3rd Fozuling Road, Donghu New&High Tech
Development Zone, Wuhan, P.R.China

Note: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)
Marque de fabrique (si elle existe)

Schneider Electric

Model / Type Ref.
Ref. De type

LC1 E40..., LC1 E40...N, LC1N40, LC1 E50..., LC1
E50...N, LC1N50, LC1 E65..., LC1 E65...N, LC1N65;

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)

The latest CB certificate No. is CN29806-M2, dated
2018-04-17. The third modification is to change the contact
size.

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

PUBLICATION **EDITION**

IEC 60947-1:2007 (5th Edition) + AMD1:2010; IEC
60947-4-1:2009(3rd Edition) + AMD 1:2012

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

00901-CB2013CQC-056228-M3

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



CHINA QUALITY CERTIFICATION CENTRE

Date: May.30,2018

Signature: Wang Kejiao

LC1 E40..., LC1 E40...N, LC1N40, LC1 E50..., LC1 E50...N, LC1N50, LC1 E65...,
LC1 E65...N, LC1N65;
Ui: 690V;
LC1 E40...N, LC1N40:
Ith: 60A;
AC-3: Ue/Ie: 220V/230V/40A, 380V/40A, 660V/34.6A;
AC-4: Ue/Ie: 220V/230V/33.3A, 380V/33.3A, 660V/28.8A;
LC1 E40...:
Ith: 60A;
AC-3: Ue/Ie: 220V/230V/40A, 380V/40A, 400V/415V/35A;
AC-4: Ue/Ie: 220V/230V/33.3A, 380V/33.3A, 400V/415V/29.2A;
LC1 E50...N, LC1N50:
Ith: 80A;
AC-3: Ue/Ie: 220V/230V/50A, 380V/50A, 660V/37.4A;
AC-4: Ue/Ie: 220V/230V/41.7A, 380V/41.7A, 660V/31.2A;
LC1 E50...:
Ith: 70A;
AC-3: Ue/Ie: 220V/230V/50A, 380V/50A, 400V/415V/41A;
AC-4: Ue/Ie: 220V/230V/41.7A, 380V/41.7A, 400V/415V/34.2A;
LC1 E65...N, LC1N65:
Ith: 80A;
AC-3: Ue/Ie: 220V/230V/65A, 380V/65A, 660V/42A;
AC-4: Ue/Ie: 220V/230V/54.2A, 380V/54.2A, 660V/35A;
LC1 E65...:
Ith: 80A;
AC-3: Ue/Ie: 220V/230V/65A, 380V/65A, 400V/415V/55A;
AC-4: Ue/Ie: 220V/230V/54.2A, 380V/54.2A, 400V/415V/45.9A;
Us: AC24V, 36V, 48V, 110V, 220V, 240V, 380V, 415V, 440V 50Hz;
AC24V, 110V, 220V, 380V, 440V 60Hz;
AC24V, 48V, 110V, 220V, 230V, 380V 50/60Hz;
3P;
IP20;

Page 1 of 1

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: May.30,2018

Signature:



Wang Kejiao