



Ref. Certif. No.

CN47576

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Auxiliary Contacts

Name and address of the applicant

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS
31 rue Pierre Mendès-France 38320 EYBENS, France

Name and address of the factory

Satys Electric (Thailand) Company Limited
55/20, 77 Moo 15 Tambon Bangsaothong, Amphur
Bangsaothong, Samutprakarn, 10570 Thailand

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark (if any)

Schneider electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

PF Standard, PF Low Level

Additional information (if necessary may also be reported on page 2)

IEC 60947-5-1:2016(4th Edition)

A sample of the product was tested and found to be in conformity with

00901-CB2016CQC-071819

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>



Signature:

Lu Mei

CB 0053636

PF Standard, PF Low Level

PF Standard:

Uimp:6kV;

Ui:480V;

Ith:5A;

Ue/Ie:

AC-12:AC240V/5A,380V/5A,480V/2A;

DC-12:DC24V/3A,48V/3A,125V/0.3A,250V/0.15A;

PF Low Level:

Uimp:6kV;

Ui:250V;

Ith:3A;

Ue/Ie:

AC-12:AC24V/48V/3A,240V/3A;

DC-12:DC24V/3A,48V/3A,125V/0.3A,250V/0.15A

Page 1 of 1

Additional information (if necessary)

Date: Aug.09,2019

Signature: 

Lu Mei