

IEC

IECEE  
CB  
SCHEME

Ref. Certif. No.

CN47701

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

Auxiliary Contacts

Name and address of the applicant

Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS  
31 rue Pierre Mendès-France 38320 EYBENS, France

Name and address of the factory

Schneider Electric Alpes  
Voie Isaac Newton ZI Alpespace, Parc D'activities Alpespace,  
Francin, 73800, France

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark (if any)

Schneider electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SDE Standard, SDE Low Level

Additional information (if necessary may also be reported on page 2)

IEC 60947-5-1:2016(4th Edition)

A sample of the product was tested and found to be in conformity with

00901-CB2016CQC-071864

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>



Date: Aug.09,2019

Signature:

Lu Mei

CB 0053639

## SDE Standard:

Uimp:8kV;

Ui:480V;

Ith:6A;

Ue/Ie:

AC-12:AC240V/6A,380V/6A,480V/2A;

DC-12:DC24V/3A,48V/3A,125V/0.3A,250V/0.15A;

## SDE Low Level:

Uimp:8kV;

Ui:250V;

Ith:3A;

Ue/Ie:

AC-12: AC24V/48V/3A,240V/3A;

DC-12:DC24V/3A,48V/3A,125V/0.3A,250V/0.15A

Additional information (if necessary)

Date: Aug.09,2019

Signature: 

Lu Mei