



Ref. Certif. No.

**FI 5711 A2**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE****CERTIFICAT D'ESSAI OC**Product  
Produit

Switch-diconnector-fuse

Name and address of the applicant  
Nom et adresse du demandeurSchneider Electric Industries SAS  
35, rue Joseph Monier  
92500 RUEIL MALMAISON, FRANCEName and address of the manufacturer  
Nom et adresse du fabricantSchneider Electric Industries SAS  
35, rue Joseph Monier  
92500 RUEIL MALMAISON, FRANCEName and address of the factory  
Nom et adresse de l'usine

See page 2

Note: When more than one factory, please report on page 2  
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page Additional Information on page 2Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

See pages 2 - 3

Trademark (if any)  
Marque de fabrique (si elle existe)Type of Manufacturer's Testing Laboratories used  
Type de programme du laboratoire d'essais constructeur

CTF stage 2

Model / Type Ref.  
Ref. De type

INFB200 3P, INFD200 3P, INFD200 4P, INFB200 4P

Additional information (if necessary may also be reported  
on page 2)Les informations complémentaires (si nécessaire,, peuvent  
être indiqués sur la 2<sup>ème</sup> pageThis certificate replaces certificate CB FI 5711 A1 dated,  
28 January 2014, due to updated standards and changed  
name of the manufacturing site.

See pages 2 - 3

 Additional Information on page 2A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à laIEC 60947-3:2008 (Third Edition) + A1:2012 in conjunction  
with IEC 60947-1:2007 (Fifth Edition) + A1:2010 + A2:2014  
EN 60947-3:2009 + A1:2012 in conjunction with  
EN 60947-1:2007 + A1:2011 + A2: 2014

274740-2 and 274740-2 Amendment 1

As shown in the Test Report Ref. No. which forms part of  
this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce CertificatThis CB Test Certificate is issued by the National Certification Body of Finland  
Ce Certificat d'essai OC est établi par l'Organisme National de Certification de Finlande

(SGS Fimko's ref.no. 284941-1 )

Date: 21 June 2016

Signature:

  
Seppo Lautamies  
Project Manager

Name and address of the factory  
Nom et adresse de l'usine

ABB Oy Protection and Connection  
Muottitie 2 A  
FI-65320 VAASA, FINLAND

Additional information  
Les informations complémentaires

Conventional free air thermal current	lth:	200 A (17 W)
Conventional enclosed thermal current	lthe:	200 A (15 W)
Number of poles		3 or 4
Rated insulation voltage:	Ui:	1000 V
Rated impulse withstand voltage:	Uimp:	12 kV
Rated operational voltage:	Ue:	690 V
Rated frequency:	f:	50 – 60 Hz
Rated operational current:	le:	200 A
Utilization category/		AC-21A, AC-22A, AC-23A
Rated short-time withstand current, I <sub>cw</sub> (r.m.s.):	1 s; 8 kA	(with solid knives)
Rated short-circuit making capacity I <sub>cm</sub> (peak):	690V:14 kA	(with solid knives)
Rated conventional short circuit current:	<u>3-pole</u>	
	415 V:	50 kA, gM 200 A (200M315)
	415 V:	80 kA, gM 200 A (200M250)
	500 V:	100 kA, gG 250 A
	690 V:	80 kA, gG 200 A, gM 200 A (200M250)
	<u>4-pole</u>	
	500 V:	100 kA, gG 200 A

Certificate for types

Type designation	Commercial number		
	Switch	Door mounted handle	Direct mounted handle
INFD200 3P	LV480500	49619 (grey)	LV480532 (grey)
INFD200 4 P	LV480501 / LV480502		LV480533 (yellow)
INFB200 3P	LV480515		LV480530 (grey)
INFB200 4 P	LV480516		LV480531 (yellow)

Additional information (if necessary)  
Information complémentaire (si nécessaire)

SGS Fimko Ltd

Date: 21 June 2016

Signature:

  
Seppo Lautamies  
Project Manager



Additional information  
Les informations complémentaires

Type designation

<b>INF</b>	<b>B</b>	<b>200</b>	<b>3P</b>	
				<b>Number of poles</b>
				3P 3 poles
				4P 4 poles
				<b>Switch size</b>
				200
				<b>Fuse type</b>
				B BS
				D DIN
				INF Switch Disconnecter Fuse

Additional information (if necessary)  
Information complémentaire (si nécessaire)

Date: 21 June 2016

Signature:

**SGS Fimko Ltd**

  
Seppo Lautamies  
Project Manager

**SGS**