

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

## Product

Switch-disconnectors

## Name and address of the applicant

**SCHNEIDER ELECTRIC INDUSTRIES SAS**  
35, rue Joseph Monier CS 30323  
92506 RUEIL-MALMAISON - FRANCE

## Name and address of the manufacturer

**SCHNEIDER ELECTRIC INDUSTRIES SAS**  
31 rue Pierre Mendès France, Eybens  
38050 GRENOBLE Cedex 9 - FRANCE

## Name and address of the factory

**Schneider Shanghai Power Distribution Elec.App.Co. Ltd**  
833 Kang Qiao Road Pudong Area  
201315 SHANGHAI - CHINA*Note: When more than one factory, please report on page 2* Additional Information on page 2

## Ratings and principal characteristics

Number of poles: 3P,4P  
Ue: AC 440V  
Rated frequency: 50/60Hz  
Ith=Ie: 630A, 800A, 1000A, 1250A, 1600A  
Utilization category: AC-23A  
Ui: 1000V, Uimp: 12kV  
Icw: 35kA/0,5s, Icm: 75kA

## Trademark (if any)



## Customer's Testing Facility (CTF) Stage used

/

## Model / Type Ref.

Series: EasyPact  
References: MVS06NA, MVS08NA, MVS10NA, MVS12NA,  
MVS16NA

Additional information (if necessary may also be reported on page 2)

 Additional Information on page 2


A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007(ed.5) +A1:2010 +A2:2014  
IEC 60947-3:2008 +A1:2012 +A2:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

1811990003

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15745284 €  
RCS Nanterre 4408563174  
33 Avenue du Général Leclerc  
F – 92266 FONTENAY AUX ROSES

Date: 30/05/2018

Signature: **Jean-François BRUEL**  
Certification Officer