

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnector

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS
35, rue Joseph Monier, CS 30323
92506 RUEIL-MALMAISON - FRANCE

Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS
31 rue Pierre Mendès France, Eybens
38050 GRENOBLE Cedex 9 - FRANCE

Name and address of the factory

See Annex

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

Ue: 690V AC
Ith=Ie: 800 A, 1000 A, 1250 A, 1600 A, 2000 A, 2500 A,
3200 A, 4000 A
Ui: 1000 V ; Uimp: 12kV
Utilization category: AC-23A
Icw:
MVSxxNA: 50 kA / 1 s (for Ie = 800 A to 3200 A); 55 kA / 1 s
(for Ie = 4000 A)
MVSxxHA: 65 kA / 1 s

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

EasyPact MVSxxNA series, EasyPact MVSxxHA series
(xx can be 08,10, 12, 16, 20, 25, 32 or 40, representing the
rated current 800 A, 1000 A, 1250 A, 1600 A, 2000 A, 2500 A,
3200 A or 4000 A respectively)

Additional information (if necessary may also be reported on page 2)

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007(ed.5) +A1:2010 +A2:2014
IEC 60947-3:2008 +A1:2012 +A2:2015


As shown in the Test Report Ref. No. which forms part of this Certificate

3308446.50 and 3303048.50 (related to CBTC No. NL-37739),
1811990020.

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 24/07/2018

Signature: **Jean-François BRUEL**
Certification Officer



Ref. Certif. No.

FR_703393

ANNEX

Name and address of the factories:

Schneider Shanghai Power Distribution Elec.App. Co. Ltd


833 Kang Qiao Road Pudong Area
201315 SHANGHAI
CHINA

Schneider Electric India Private Limited

Survey #215, Gagillapur Village, Medak Road
HYDERABAD ANDHRA PRADESH
INDIA



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 24/07/2018

Signature: **Jean-François BRUEL**
Certification Officer