



# CB TEST CERTIFICATE

Ref. Certificate No.

NL-37740

## IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Air Circuit Breaker		
Applicant:	Schneider Electric Industries SAS	35, rue Joseph Monier FR-92500 RUEIL-MALMAISON	France
Manufacturer:	Schneider Electric Industries SAS	35, rue Joseph Monier FR-92500 RUEIL-MALMAISON	France
Factory:	Schneider Shanghai Power Distribution Elec. App. Co., Ltd	No.833 Kangqiao Road, Pudong, Shanghai	China
nb: Additional factory information on page 2			
Rating and principal characteristics:	Ue: 220 / 440 Vac, 690 Vac EasyPact MVSxxN In: 800, 1000, 1250, 1600, 2000, 2500, 3200, 4000 A EasyPact MVSxxH In: 630, 800, 1000, 1250, 1600, 2000, 2500, 3200, 4000 A 50 / 60 Hz Ui = 1000 V Uimp = 12 kV See annex for further ratings		
Trade mark (if any):	SCHNEIDER ELECTRIC		
Model/Type reference:	EasyPact MVSxxN / H series		
Additional information:	This certificate is based on CB NL-24196 issued on 2012-08-07		
Sample of product tested to be in conformity with IEC:	Standard(s): 60947-2(ed.4);am1;am2		
Test Report Ref. No:	3308447.50, 3303047.50		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.  
Meander 1051, 6825 MJ  
Arnhem  
The Netherlands

Signed by: H.L. Schendstok

Date of issue: 2015-11-17



**Schneider Electric India Private Limited**  
Survey #215, Gagillapur Village, Medak Road,  
Hyderabad, Andhra Pradesh  
**India**

Additional information (if necessary)

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.  
Meander 1051, 6825 MJ  
Arnhem  
The Netherlands

Signed by: H.L. Schendstok

Date of issue: 2015-11-17

