

**IEC****IECEE**

®

TM

Ref. Certif. No.

HU-003303

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Direct on-line starter and reverser starter
Name and address of the applicant	Schneider Electric SE 35 rue Joseph Monier 92500 Rueil Malmaison, France
Name and address of the manufacturer	Schneider Electric 31 Rue Pierre Mendès France, Eybens 38050 Grenoble Cedex 09, France
Name and address of the factory	See additional page(s)
Ratings and principal characteristics	Rated operational voltage Ue: 690V/400V; Rated current: 9A - 65A; Rated frequency: 50/60Hz; Rated insulation voltage Ui: 690V; Rated impulse withstand voltage Uimp: 6kV; (see Test Report for further Ratings)
Trademark (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	LE1D series, LE2D series
Additional information (if necessary may also be reported on page 2)	(See further details in Test Report)
A sample of the product was tested and found to be in conformity with	IEC 60947-4-1:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	28241115 001

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., MEEI Division  
H-1143 Budapest, Gizella út 51-57., Hungary  
Web: www.tuv.com

Date: 2021-05-14

Signature: Gábor Kassai

1. Schneider Electric France  
6 - 8 rue du Bailly, BP 97812  
21078 DIJON Cedex  
France
2. Schneider Electric Industries S.A.  
ZAC Le Village  
27100 Le Vaudreuil  
France

**Additional information (if necessary)**

Report Ref. No. : 28241115 001

Date: 2021-05-14

Signature:



Gábor Kassai