

IEC**IECEE**

®

TM

Ref. Certif. No.

HU-003460

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

| | |
|---|---|
| Product | Star-delta starter |
| Name and address of the applicant | Schneider Electric SE 35 rue Joseph Monier 92500 Rueil Malmaison, France |
| Name and address of the manufacturer | Schneider Electric 31 Rue Pierre Mendès France, Eybens 38050 Grenoble Cedex 09, France |
| Name and address of the factory | Schneider Electric France 6 - 8 rue du Bailly, BP 97812 21078 DIJON Cedex, France |
| Ratings and principal characteristics | Rated operational voltage Ue: 440V; Rated frequency: 50/60Hz; Rated insulation voltage Ui: 440V; Rated impulse withstand voltage Uimp: 6kV; (see Test Report for further Ratings) |
| Trademark (if any) | Schneider Electric |
| Customer's Testing Facility (CTF) Stage used | N/A |
| Model / Type Ref. | LE3D series |
| Additional information (if necessary may also be reported on page 2) | (See further details in Test Report) |
| A sample of the product was tested and found to be in conformity with | IEC 60947-4-1:2018 |
| As shown in the Test Report Ref. No. which forms part of this Certificate | 28244582 001 |

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2021-06-04

Signature: Gábor Kassai