

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Circuit-breakers for overcurrent protection for household and similar installations

SCHNEIDER ELECTRIC INDUSTRIES SAS 31 rue Pierre Mendès France, Eybens

F-38050 Grenoble Cedex 9

France

SCHNEIDER ELECTRIC INDUSTRIES SAS

31 rue Pierre Mendès France, Eybens

F-38050 Grenoble Cedex 9

France

Additional information on page 2

SCHNEIDER ELECTRIC BULGARIA EOOD

Plovdiv plant 4202 Radinovo Bulgaria

2P; Ue = 230 V; 50-60 Hz; Icn = 3000 A Curve C – In = 6, 10, 16, 20, 25 and 32 A

(see also pages 7 and 9 of Test Report No. PB21-0064945-01-00

and/or Additional Sheet)

Schneider Electric

Schneider Electric

Resi9 XE series

(see also page 9 of Test Report PB21-0064945-01-00 or Additional Sheet)

Additional information on page 2

IEC 60898-1:2015, IEC 60898-1:2015/AMD1:2019

National differences:

EU Group Differences

PB21-0064945-01-00 and from PB21-0064945-01-01 to PB21-0064945-01-06

This CB Test Certificate is issued by the National Certification Body

IMQ S.p.A.

Via Quintiliano 43, IT-20138 Milano, Italy



Date: 2021-10-11 Signature: Mauro Casari



Description of the circuit-breakers for overcurrent protection Resi9 XE series

Curve	Rated current	Generic reference
С	6 A	R9E3DOM2C6
	10 A	R9E3DOM2C10
	16 A	R9E3DOM2C16
	20 A	R9E3DOM2C20
	25 A	R9E3DOM2C25
	32 A	R9E3DOM2C32

The circuit-breakers for overcurrent protection Resi9 XE series are suitable to be mounted on the following bases for plug-in connection:

Generic reference	Designation	Description	
R9XEDOMCP8	Distri 8M Screw		
R9XEDOMCP13	Distri 13M Screw	With screw for conductor connection	
R9XEDOMCP18	Distri 18M Screw		
R9XEDOMSP8	Distri 8M		
R9XEDOMSP10	Distri 10M	Without screw for conductor connection	
R9XEDOMSP13	Distri 13M	Conductor Connection	

Mod. 3272/0 page 1 of 1