

IEC**IECEE**

®

TM

Ref. Certif. No.

CN52920

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Auxiliary Contact Block

Name and address of the applicant

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP
Muka Kuning Kel.Muka Kuning Kec. Sungai Beduk – Batam,
Indonesia*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Ui:690V;Ith=10A;AC-15: Ue/Ie: 120V/6A, 690V/1.04A;DC-13: Ue/Ie:
125V/0.55A, 600V/0.1A;IP20(except for contact block without terminal cover :
IP00)

Trademark / Brand (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

LAD8N;

Additional information (if necessary may also be reported on page 2)

IEC 60947-5-1:2016(4th Edition)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

00901- CB2020CQC-095403

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Mar.01,2021

Signature:

Lu Mei

CB 0061406