



Ref. Certif. No.

HU-002657

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

AC Contactor for capacitive applications

Name and address of the applicant

Schneider Electric SE
35, rue Joseph Monier, 92500 Rueil Malmaison
France

Name and address of the manufacturer

Schneider Electric Industries SAS
31 rue Pierre Mendès France, Eybens 38320
France

Name and address of the factory

Schneider Electric a. s.
Cizovska 447, 39701 Pisek
Czech Republic

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Operating power AC6b: 104, 87,1 kvar (690V);
Ue: 230V, 400-415V, 440V, 550V, 690V; 50/60Hz
Degree of protection: IP20
(For details see test report)

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

LC1DVK12
(For details see test report)

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

28250172 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.com

Date: 2019-07-15

Signature:

Ferencné Schmidt

