



# CB TEST CERTIFICATE

Ref. Certificate No.

NL-34959

## IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Surge protective devices		
Applicant:	Schneider Electric Industries SAS	Electropole 38EQI, 31 rue Pierre Mendes 38050 Grenoble Cedex 9	France
Manufacturer:	Schneider Electric Industries SAS	Electropole 38EQI, 31 rue Pierre Mendes 38050 Grenoble Cedex 9	France
Factory:	Schneider Electric Hungaria	Villamosagi Zrt. Hock János út. 55, 8900, Zalaegerszeg,	Hungary
Rating and principal characteristics:	Uc= 264/350 V, In= 2/5/20 kA, I <sub>max</sub> = 8/20/40 kA, Up= 1,2/1,5/1,7/2,5 kV (for overview of ratings, see page 4 of test report)		
Trade mark (if any):	SCHNEIDER ELECTRIC		
Model/Type reference:	iQuick PRD 8r... iQuick PRD 20r... iQuick PRD 40r... (for overview of types, see page 4 of test report)		
Additional information:			
Sample of product tested to be in conformity with IEC:	61643-11(ed.1)		
Test Report Ref. No:	2170494.50, 2170494.51, 2170494.52		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.  
Meander 1051, 6825 MJ  
Arnhem  
The Netherlands

Signed by: F.S.Strikwerda

Date of issue: 2015-02-13

