



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2011010305501943

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric South East Asia (HQ) Pte Ltd
10, Ang Mo Kio Street 65, #02-01/06, Techpoint, Singapore 569059

NAME AND ADDRESS OF THE MANUFACTURER

P T Schneider Electric MFG Batam
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

NAME AND ADDRESS OF THE FACTORY

P T Schneider Electric MFG Batam
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

NAME, MODEL AND SPECIFICATION

Safety Limit Switch

XCS-A; Ui:500V;Ith:10A;AC-15:Ue/Ie:AC240V/3A;DC-
13:Ue/Ie:DC250V/0.27A;IP67;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Sep.28, 2016 Date of expiry: Sep.28, 2021

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Sep.29, 2011

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1511994



中国国家强制性产品认证证书

证书编号: 2011010305501943

委托人名称、地址

Schneider Electric South East Asia (HQ) Pte Ltd
10, Ang Mo Kio Street 65, #02-01/06, Techpoint, Singapore 569059

生产者(制造商)名称、地址

P T Schneider Electric MFG Batam
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

生产企业名称、地址

P T Schneider Electric MFG Batam
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

产品名称和系列、规格、型号

安全限位开关

XCS-A; Ui:500V;Ith:10A;AC-15:Ue/Ie:AC240V/3A;DC-13:Ue/Ie:DC250V/0.27A;防护等级:IP67; 型号详见附件

产品标准和技术要求

GB 14048.5-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求,特发此证。

发证日期: 2016年09月28日 有效期至: 2021年09月28日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期: 2011年09月29日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1511994



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2011010305501943

纸号: 1511994

型号的解释:

$\frac{XCS-}{I}$	$\frac{A}{II}$	$\frac{5}{III}$	$\frac{0}{IV}$	$\frac{3}{V}$
I-	Product type 产品型号 XCS safety limit switch XCS 安全限位开关			
II-	Type of interlocking 联锁形式 A - Without locking of key A - 无锁			
III-	Type of contact block 触头形式 5 - 1 NC + 2 NO 7 - 2 NC + 1 NO 8 - 3 NC			
IV-	LED 0 - Without 无 LED			
V-	Type of entry 接口形式 1 - Threaded hole for Type 13 European cable gland 13 号欧洲电缆密封管螺纹孔 2 - Threaded hole for ISO cable gland ISO 电缆密封管螺纹孔 3 - 1/2 in. NPT threaded hole 1/2 in. NPT 螺纹孔			

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

