



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2011010305501943

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Asia Pte Ltd
50 Kallang Avenue, Singapore 339505

NAME AND ADDRESS OF THE MANUFACTURER

PT. Schneider Electric Manufacturing Batam
JI Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning
Kec. Sungai Beduk – Batam, Indonesia

NAME AND ADDRESS OF THE FACTORY

PT. Schneider Electric Manufacturing Batam
JI Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning
Kec. Sungai Beduk – Batam, Indonesia

PRODUCT NAME, MODEL AND SPECIFICATION

安全限位开关

XCSA: Ui:500V;Uimp:6kV;lth:10A; AC-15: Ue/le:AC240V/3A;DC-13: Ue/le:DC250V/0.27A;l
P67

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.30,2019

Valid until: Sep.28,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Sep.29,2011

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

证书编号：2011010305501943

委托人名称、地址

Schneider Electric Asia Pte Ltd
50 Kallang Avenue, Singapore 339505

生产者（制造商）名称、地址

PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka
Kuning Kel.Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

生产企业名称、地址

PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka
Kuning Kel.Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

产品名称和系列、规格、型号

安全限位开关

XCSA: Ui:500V;Uimp:6kV;lth:10A; AC-15: Ue/le:AC240V/3A;DC-13:
Ue/le:DC250V/0.27A;IP67; 型号解释见附件

产品标准和技术要求

GB/T14048.5-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，
特发此证。

发证日期：2019年05月30日 有效期至：2021年09月28日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2011年09月29日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：

陆楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2011010305501943

纸 号: 2280166

型号解释:

XCS- I	A II	5 III	0 IV	3 V
I-	产品型号 XCS 安全限位开关			
II-	联锁形式 A - 无锁			
III-	触头形式 5 - 1 NC + 2 NO 7 - 2 NC + 1 NO 8 - 3 NC			
IV-	LED 0 - 无 LED			
V-	接口形式 1 - 13 号欧洲电缆密封管螺纹孔 2 - ISO 电缆密封管螺纹孔 3 - 1/2 in. NPT 螺纹孔			

注: 此附录与证书同时使用时有效。



主 任:

陆梅



中国质量认证中心