

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE**CERTIFICAT D'ESSAI OC**

Product
Produit

Name and address of the applicant
Nom et adresse du demandeur

Name and address of the manufacturer
Nom et adresse du fabricant

Name and address of the factory
Nom et adresse de l'usine

Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Trademark (if any)
Marque de fabrique (si elle existe)

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais
constructeur

Model / Type Ref.
Ref. De type

Additional information (if necessary may also be
reported on page 2)
Les informations complémentaires (si nécessaire,,
peuvent être indiqués sur la 2^{ème} page

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

As shown in the Test Report Ref. No. which forms
part of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

Uninterruptible Power Supply, permanently connected
equipment

Schneider Electric IT Corporation, FKA APC American Power
Conversion
132 Fairgrounds Rd
PO BOX 278
West Kingston, RI 02892 USA

SCHNEIDER ELECTRIC IT DENMARK APS
SILCON ALLE 1
KOLDING, 6000 Denmark

Schneider Electric Information Technology (Xiamen) Co Ltd
1678 Jixian Rd Tongji Park Torch Hi-Tech Industrial Xiamen
Fujian 361100,
China

Additional Information on page 2
See Page 2



WMT

Galaxy VM Modular Battery Cabinet, Narrow, Galaxy VM
Modular Battery Cabinet, Wide, Galaxy VM 160 kVA, Galaxy VM
200 kVA

National Differences specified in the CB Test Report.

Additional Information on page 2

IEC 62040-1(ed.1), IEC 62040-1(ed.1);am1

478617089 issued on 2014-10-20

This CB Test Certificate is issued by the National Certification Body

Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
UL (Denko), Borupvang 5A DK-2750 Ballerup, DENMARK
UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2014-10-21

Signature:

Jan-Erik Storgaard

Factories:

American Power Conversion (Apc) Bv
2nd St Cavite Epza Rosario 4106 Cavite,
Philippines

American Power Conversion (Apc) Bv
Plant 3 Blk 16, Phase Iv, Lot 10 Peza Rosario 4106 Cavite,
Philippines

Apc India Pvt Ltd
No 18a Suvey No 128 1st Phase Jigani Industrial Area Jigani Vill. Jigani Hobil Anekaltaluk Bangalore Ka 562106,
India

Schneider Electric IT France SAS,
Inovallee 140 avenue Jean Kuntzmann, Zirst Montbonnot Saint Martin, 38334 Saint-Ismier Cedex,
FRANCE

Ratings:

Galaxy VM 200 kVA

Input: 380/400/415 V
345/328/316 A
50/60 Hz, 3W+PE / 4W+PE

Output: 380/400/415 V
304/289/278 A
50/60 Hz, 3W+PE / 4W+PE

Galaxy VM 160 kVA

Input: 380/400/415 V
278/262/253 A
50/60 Hz, 3W+PE / 4W+PE

Output: 380/400/415 V
243/231/223 A
50/60 Hz, 3W+PE / 4W+PE

Galaxy VM Modular Battery Cabinet, Narrow
Output: 480Vdc, 440Adc

Galaxy VM Modular Battery Cabinet, Wide
Output: 480Vdc, 440Adc

Additional information (if necessary)**Information complémentaire (si nécessaire)**

UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA



UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK



UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN



UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2014-10-21

Signature:



Jan-Erik Storgaard