



Certificate of Compliance

Certificate: 70091588

Master Contract: 177007 (LR 88980)

Project: 70091588

Date Issued: 2016-08-30

Issued to: Schneider Electric Industries SAS
Power Business Unit / LV
31, rue Pierre Mendes France
Eybens
Grenoble Cedex 9, 38050
FRANCE
Attention: Michael Mary

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Ronald Tateishi*
Ronald Tateishi

PRODUCTS

CLASS 4652 06 – SWITCHES - Moulded Case

Moulded case switches, Powerpact BD, BG and BJ, 2- and 3- pole, 125A, 600V ac max.

Notes:

1. These switches are Certified for use only as components of other Certified equipment where the suitability of the combination is determined by CSA Group.
2. These switches may be line-load reverse connected.
3. These switches may be marked with withstand ratings as follows:

Switch Type	S.C. Withstand Rating (kA, rms, sym)		
	D	G	J
240V ac	25	65	100
480V ac	18	35	65
600V ac	14	18	25



Certificate: 70091588

Project: 70091588

Master Contract: 177007 (LR 88980)

Date Issued: 2016-08-30

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures



Supplement to Certificate of Compliance

Certificate: 70091588

Master Contract: 177007 (LR 88980)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70091588	2016-08-30	Original Certification.