



# Certificate of Compliance

**Certificate:** 1156136

**Master Contract:** 240515

**Project:** 2024863

**Date Issued:** April 23, 2008

**Issued to:** Telemecanique/Schneider Electric

Industries SAS  
Zone Industrielle No. 3  
L'Isle d'Espagnac, 16340  
France  
Attention: Mr. Christophe Delaitre

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** Jean-Claude Chow, Eng.

**Authorized by:** Helene Vaillancourt, Operations Manager

A handwritten signature in black ink, reading 'Helene Vaillancourt'.

## **PRODUCTS**

**CLASS 3211 03** - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Miniature interlock switches, non-metallic, Models XCS-PA, -PL, -PR, -TA, -TL and -TR, followed by a three digit number, Type 4X Indoor and 12 Enclosure. Electrical ratings:

XCS-P....: A300 - Q300, when provided with a two poles contact block

B300 - R300, when provided with a three poles contact block

XCS-T....: A300 - Q300

## **APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No. 14-05 - Industrial Control Equipment



**Certificate:** 1156136

**Master Contract:** 240515

**Project:** 2024863

**Date Issued:** April 23, 2008

---

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures