



Certificate of Compliance

Certificate: 1175009

Master Contract: 240515

Project: 70123917

Date Issued: 2017-08-03

Issued to: Telemecanique/Schneider Electric Industries SAS
Zone Industrielle No. 3
L'Isle d'Espagnac, 16340
FRANCE

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Khalil Ouldchama*
Khalil Ouldchama, P. Eng.

PRODUCTS

CLASS - C241102 - ELEVATOR EQUIPMENT-Enclosed Elevator-and Escalator Electrical Equipment

CLASS - C321103 - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers - Auxiliary Devices

PART A: (CLASS 2411 02 & CLASS 3211 03)

Limit Switches, enclosed, Types XCK-J, ZCK-J, XCL-J and XCS-L, A300, Q300 when provided with contact blocks Types XEN-P, XE2N-P, XES-P, XE2S-P; B300 or R300 when provided with contact blocks Types XE3S-P, XE3N-P; Type 4X indoor with or without magnetic latching 12V dc to 48Vdc or 110V to 240Vac.

Notes:

1. Limit switches XCK-J, ZCK-J and XCL-J equipped with M12 threaded receptacle are rated pilot light duty 30V ac/dc - 3A max.
2. These limit switches are “positive mechanical action”.
3. These limit switches when provided with contact blocks types XE3S-P, XE3N-P are certified under Class 3211-03 only.

PART B: (CLASS 3211 03)

- Limit Switches, enclosed Type 4, Type XCR, rating codes A300, Q300 for same polarity or opposite polarity.



Certificate: 1175009
Project: 70123917

Master Contract: 240515
Date Issued: 2017-08-03

- Limit switches, Type XCR, followed by A, B, E, F or T, followed by two, three or five digit numbers, With Rating of contact A300, Q300 for model XCRA, B, E or F and B300, R300 for model XCRT. Enclosure rating type 12 for model XCRA, B, E or F, type 4, 4X and 12 for model XCRA, B, E, F and for model XCRT.

APPLICABLE REQUIREMENTS

- | | | |
|--------------------------------|---|---|
| CSA-C22.2 No. 14-13 | - | Industrial Control Equipment |
| CSA-C22.2 No. 94-M91 | - | Special Purpose Enclosures |
| CSA-B44.1-14 / ASME-A17.5-2014 | - | Elevator and Escalator Electrical Equipment |