



Certificate of Compliance

Certificate: 1352446

Master Contract: 225619

Project: 2533692

Date Issued: June 12, 2012

Issued to: Telemecanique/Schneider Electric

Industries SAS.

BP 660

Zone Industrielle No. 3

L'Isle d'Espagnac, 16340

France

Attention: Mr. Jean-Pierre Laidet

The products listed below are eligible to bear the CSA Mark shown



J.-C. Chow

Issued by: J.-C. Chow

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Trip wire operated emergency stop switches, Model XY2CH, rated A300, Q300 for two-contacts (1NC+1NO or 2NC) model, or rated B300, R300 for three-contacts (2NC+1NO) model; Type 4 Enclosure.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 14-10 - Industrial Control Equipment

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures