



Certificate of Compliance

Certificate: 1573553 (LR 44087)

Master Contract: 225619

Project: 1573553

Date Issued: 2004/07/20

Issued to: Telemecanique/Schneider Electric

Industries SAS
BP 660
Zone Industrielle No. 3
L'Isle d'Espagnac, 16340
France

The products listed below are eligible to bear the CSA Mark shown



Issued by: Michel Legault, Eng.

Authorized by: Alain Ste-Marie
Operations Manager

Alain Ste-Marie

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Pressure transmitter or electronic pressure switch, Type XML-G, followed by M01 or a three digit number, followed by D, L or Q, followed by a two digit number, may be followed by a three digit number. Rated voltage all products: 12/24V dc (Class 2 input only); analog output: 4-20mA, 0-10V or 0-5V; solid state output: 150mA max. Type 4 enclosure.

Note:

1. Rated 24V dc (Class 2 input only) for products with 0-10 V analog output.



Certificate: 1573553 (LR 44087)

Master Contract: 225619

Project: 1573553

Date Issued: 2004/07/20

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 14-95 - Industrial Control Equipment

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures